

SPECIFICATIONS

Air Separators

The centrifugal air - separator will be of M.S. construction with flanged connections. The air separator will be adequately sized to achieve maximum air-separation. It will be provided with a high capacity super-vent at the top. The shell shall be fabricated as per IS 2825-1969 for “non-fired pressure vessels” and the flanges shall be as per IS 6392-1971.

For chilled water application, it will be insulated with 50 mm thick insulation to the specifications and cladded with 26G-aluminium cladding.